


Space between pressure plate and supporting column should be kept free from fixed installations!




22.74 21.46

## FRAME PLATE

39 \*) / 24 \*\*)-Recommended free space S1 for opening and closing to be applied on both sides 0 S3 S2 0 Free space can be reduced to this distance on one of the sides 7.72 16.38

All dimensions in inches



TIGHTENING BOLTS  $4 \times M20$ , L = 13.0 in  $4 \times M20$ , L = 13.0 in

APPROX. OUTER DIMENSIONS

LENGTH 25.2 in WIDTH 16.9 in HEIGHT 35.4 in APPROX. WEIGHTS

APPROX. WEIGHTS

NET WEIGHT, EMPTY 518 lb
WEIGHT FULL OF WATER 547 lb
PLATE MATERIAL ALLOY 316
PLATE THICKNESS 0.5 mm

GASKET NBRP ClipGrip™

AREA OF HEAT SURFACE 53.9 ft<sup>2</sup>

ASME B16.5 Class 150 NPS 3
S1, S2, \$30,64

A-A:
ALLOY 316

2.87

A

5/8"-11 UNC (x4)

NO. OF UNITS

10.0 GPM 9.9 GPM

DRAWING

GASKETED PLATE HEAT EXCHANGER

T8-BFG

ASME
Code Section VIII Div.1

MAWP 150 psi at 266.0 °F MDMT -18.0 °F at 150 psi

0.89

Designed, constructed and stamped in accordance with 2021 ASME.

 $\bigcirc$ 

8240152990 T8-BFG, 30 plates

Do not use this drawing for foundation bolting or piping layout

or planning of lifting and handling of the equipment.

DATE 6/13/23 REVISION 0

www.alfalaval.com

**(**