


Space between pressure plate and supporting column should be kept free from fixed installations!




FRAME PLATE

39 *) / 24 **)-Recommended S4 S1 🔘 free space for opening **₹** and closing to be applied on both sides S2 **S**3 Free space can be reduced to this distance on one of the sides

12.6

All dimensions in inches



TIGHTENING BOLTS

 $4 \times M20$, L = 13.0 in $2 \times M20$, L = 13.0 in


APPROX. OUTER DIMENSIONS LENGTH 25.6 in **WIDTH** 13.0 in HEIGHT 34.6 in APPROX. WEIGHTS


NET WEIGHT, EMPTY 370 lb WEIGHT FULL OF WATER 402 lb PLATE MATERIAL ALLOY 316 PLATE THICKNESS 0.5 mm

GASKET NBRP ClipGrip™

AREA OF HEAT SURFACE 52.2 ft²

ASME B16.5 Class 150 NPS 2 S1, S2, S3, S4





-5/8"-11 UNC (x4)

NO. OF UNITS **CHANNEL**

MH ML

10.0 GPM 9.9 GPM

DRAWING

GASKETED PLATE HEAT EXCHANGER

ASME

MAWP 150 psi at 266.0 °F

Designed, constructed and stamped in accordance with 2021 ASME.

8240152963 T6-PFG, 35 plates,

Do not use this drawing for foundation bolting or piping layout

or planning of lifting and handling of the equipment.

DATE 6/13/23 **REVISION**

www.alfalaval.com

MDMT -18.0 °F at 150 psi

Code Section VIII Div.1